

Addendum

Florida Gateway College
 Building 10 – Exterior Improvements
 Lake City, Florida
 FGC Bid Number: ITB No. 20-5-01

Project

2002

KP Project Number

May 15, 2020

Date

Page 1 of 1

Pages

N/A

Attachments

Two

Addendum Number

This Addendum shall be considered part of the Contract Documents and shall be incorporated integrally into them. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall take precedence. Bidders shall acknowledge receipt of this Addendum on their Bid Form.

1. **PROJECT MANUAL, SECTION 06 1053 – MISCELLANEOUS ROUGH CARPENTRY:** Refer to Paragraph 2.3, Subparagraph B. The new plywood is not required to be pressure treated.
2. **PROJECT MANUAL, SECTION 07 4213 – METAL WALLS:** Refer to Paragraph 2.2, Subparagraph B. The new Basis-of-Design product shall be: ATAS International, Inc.; Multi-Purpose Panel – MPW080.
3. **DRAWINGS, SHEET A-3 – WALL SECTIONS AND DETAILS:** Refer to the Details. Air-Shield Self-Adhering Air/Vapor and Liquid Moisture Barrier by W.R. Meadows is an acceptable substitution for the new self-adhered underlayment.

END OF ADDENDUM